

Maximum	520	1332	6890	46	1.1	64.0	20.0	170
Average	68	633	1940	19	0.286	27.5	7.8	57
Median	28	620	1000	20	0.216	27.5	7.6	49
Minimum	8	306	52	-	-	9.1	3.4	14

2.6 Treated Wastewater Quality at Kepler Block

The quality of the treated wastewater is, in general, not expected to change significantly between the Te Anau WWTP and the Kepler Block.

There is however a high likelihood that the treated wastewater could become anaerobic given the distance over which the pipeline will convey the treated wastewater. This situation could make the treated wastewater a potential source of odour. Measures for reducing or removing the odour source are discussed in Section 7.5.2 and include additional aeration, chemical dosing and irrigation methods.